

IREDELL COUNTY HEALTH DEPARTMENT

Auth. to Construct
STATESVILLE 704-878-5305

MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 26139 DATE 4/15/97 TAX MAP NO. 4637086330 Watershed: ☒ Yes ☐ No

OWNER OR CONTRACTOR James M. Harper PHONE: Business 478-3766 Home _____

ADDRESS 1651 Ledge Forest Dr. Cataula, GA. 28609



LOCATION 150W TL Quiet Cove TL Trollingwood; 2nd lot on R

SUBDIVISION Spring Breeze BLOCK / SECTION _____ LOT 42 LOT AREA .75 AC SITE CLASS. RS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: <u>1000</u> Gallons; STB <u>1000</u> Date <u>7/2/97</u>	☒ New System ☐ Repair System Type: I, II, III, IV, V, VI	☒ House/Mod. Home No. Bedrooms <u>3</u>	Water Supply: ☒ Individual ☐ Community ☐ Public
Pump Tank: _____ Gallons; PT _____ Date _____	System Description: <u>CH PLASTIC</u>	☐ Mobile Home No. Bathrooms <u>2</u>	
Pump Make: _____ Model _____ Serial No. _____	Repair System Description: <u>Pressure Panel</u>	☐ Business No. Employees _____	
Nitrification Field: No Fields <u>1</u> Square Feet <u>900*</u> Linear Feet <u>300*</u>	Maintenance Agreement Required: ☐ Yes ☒ No	☐ Other _____	
No Lines <u>3</u> Trench Width <u>36"</u> Max Trench Bottom Depth <u>36"</u>	Gravel Depth <u>SAND</u> ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing		

Comments: * 25% reduction for Ch. Plastic use
1" = 50' 20'

Comments:



I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed: James M. Harper Installed by: Chuck Kennedy

Improvement Permit by: Wesley Sparks RS. date 4/15/97 Certificate of Completion by: Wesley Sparks RS. date 9/16/97

Existing System Inspection by: Wesley Sparks RS date 4/15/97 Operation Permit by: Wesley Sparks RS. date 9/16/97

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD