

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305

MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 132193 PIN# 4637086593 DATE 12-5-05

OWNER OR APPLICANT Traditional Southern Homes PHONE: Business 980-721-5434 Home _____

ADDRESS 8533 Glade Ct Huntersville 28078



LOCATION Hwy 150 W TL Quiet Cove, TL Trollingwood Ln on left

SUBDIVISION Spring Acres BLOCK / SECTION _____ LOT 23 LOT AREA .545 AC SITE CLASS. P5 DESIGN FLOW 480 L.T.A.R. .25 gpd/ft²

Septic Tank: <u>1000</u> Gallons: STB <u>794</u> Date <u>2-21-06</u>	☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI	☒ House/Mod. Home No. Bedrooms <u>4</u>	Water Supply: ☒ Individual
Pump Tank: _____ Gallons: PT _____ Date _____	System Description: <u>Panel Block, Gravity</u>	☐ Mobile Home No. Persons _____	☐ Public
Pump Make: _____ Model _____ Serial No. _____	Repair System Description: <u>LP Panel</u>	☐ Business No. Employees _____	☐ Community
Nitrification Field: No Fields <u>1</u> Square Feet <u>1920</u> Linear Feet <u>320</u>	Maintenance Agreement Required: ☐ Yes ☒ No	☐ Other _____	
No Lines <u>6</u> Trench Width <u>24"</u> Max Trench Bottom Depth <u>36"</u>	Gravel Depth <u>NA</u> ☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing		

Comments/Conditions: 6 lines, 12 panels per line
Flow divider with 2 D-Boxes containing polylok
equalizer speed levelers

Comments/Conditions: Tanks checked 5-30-06
filter not in
6-2-06 Red polylok filter



Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit - not to exceed sixty months.

Signed: Christopher Tucker date 12-6-05 Installed by: Gerald Tucker Septic

Improvement Permit by: Judy Merrill date 12-5-05 Operation Permit by: Judy Merrill date 6-6-06

Authorization to Construct by: Judy Merrill date 12-5-05 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK