

# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305

MOORESVILLE 704-664-5281



## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 116954 PIN# 4637-17-0348 DATE 1/8/04  
 OWNER OR CONTRACTOR Scott Lee - PRIDE HOMES PHONE: Business 704-819-7228 Home \_\_\_\_\_  
 ADDRESS 601 Barber Loop Mooresville, NC 28117  
 LOCATION 150' N to Quiet Cove Tr, Trollingwood on (L) just past Basswood Ln  
 SUBDIVISION Springhaus BLOCK / SECTION \_\_\_\_\_ LOT 11 LOT AREA ~.50 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. 3

Septic Tank: <u>1000</u> Gallons; STB <u>1012</u> Date <u>6/1/04</u>	<input checked="" type="checkbox"/> New System <input type="checkbox"/> Repair System Type: I, II, <u>IV</u> , V, VI	<input checked="" type="checkbox"/> House/Mod. Home No. Bedrooms <u>4</u>	Water Supply: <input checked="" type="checkbox"/> Individual <input type="checkbox"/> Public <input type="checkbox"/> Community
Pump Tank: _____ Gallons; PT _____ Date _____	System Description: <u>GRAVITY - 16" PPBS</u>	<input type="checkbox"/> Mobile Home No. Bathrooms <u>2.5</u>	
Pump Make: _____ Model _____ Serial No. _____	Repair System Description: <u>&lt; 83 RECORDED</u>	<input type="checkbox"/> Business No. Employees _____	
Nitrification Field: No Fields <u>1</u> Square Feet <u>534/801</u> Linear Feet <u>267</u>	Maintenance Agreement Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Other _____	
No Lines <u>5 @ 53</u> Trench <u>2-3'</u> Max Trench Bottom Depth <u>36"</u>	Gravel Depth <u>N/A</u> <input type="checkbox"/> Slab <input type="checkbox"/> Crawl Space <input checked="" type="checkbox"/> Basement w/plumbing <input type="checkbox"/> Basement wo/plumbing		

Comments/Conditions: 2' on 8' Centers / 3' on 9' Centers

Comments/Conditions: \*RECORDED DEED ATTACHED



Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit - not to exceed sixty months.

Signed: Scott Lee date 2/3/04 Installed by: C+S Dredging  
 Improvement Permit by: Wendy Sparks RS. date 1/8/04 Operation Permit by: Wendy Sparks RS. date 11/30/04  
 Authorization to Construct by: Wendy Sparks RS. date 1/8/04 Existing System Inspection by: \_\_\_\_\_ date \_\_\_\_\_